



INSPECTION OFFICER ORDER NO. RCT - 1 - 2015

IN THE MATTER OF THE *NATIONAL ENERGY BOARD ACT*, AN ORDER UNDER SECTION 51.1

Full name of the recipient

is employed by Westcoast Energy Inc. carrying on business as Spectra Energy Transmission

On 26 November 2015, the undersigned *National Energy Board* Inspection Officer received information regarding a release of a toxic substance (amine).

The Inspection Officer has reasonable grounds to believe:

That the health and safety of the employees at the Pine River Gas Plant may have been compromised and that continued operation of the plant could pose a further risk to their safety.

Based on the above mentioned, the inspection officer has reasonable grounds to believe that a hazard to the safety or security of the public, or employees of a company or a detriment to property or the environment is being or will be caused by the construction, operation, maintenance or abandonment of the pipeline, or excavation activity or construction of a facility as per 49(2)(a).


Therefore, _____ is HEREBY ORDERED,
Full name of the recipient

pursuant to section 51.1 of the *National Energy Board Act*, to

- | | |
|---|--|
| <input type="checkbox"/> take measures specified below for guarding the safety or security of the public or employees or protecting property or the environment | <input checked="" type="checkbox"/> Suspend work until the hazard or detrimental situation has been remedied to the satisfaction of the inspection officer; or the order is stayed or rescinded by the Board |
|---|--|

Specified Measures: Maintain complete shutdown of the Pine River Gas Plant until the following measures have been completed:

- A preliminary investigation shall be conducted and the following shall be submitted to the Inspection Officer:
 - Event summary complete with piping & instrumentation and process flow diagrams;
 - Immediate and root causes;
 - Determination of whether the event is also applicable to gas processing trains A&B;
 - Corrective actions including time lines; and
 - A start-up plan.
- The plant, in whole or in part, shall not be re-started unless express permission to do so has been provided by an Inspection Officer



Inspection Officer	#0994	
	IO Designation #	
	26 November 2015	
	Date	
517 10th Avenue SW Calgary AB T2R 0A8		